



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx NEM 14.0012X Issue No: 0 Certificate history:  
Issue No. 0 (2014-11-06)

Status: **Current** Page 1 of 4

Date of Issue: **2014-11-06**

Applicant: **Moflash Signalling Ltd**  
Unit 18 Klaxon Industrial Estate, Tyseley  
Birmingham B11 2HA.  
**United Kingdom**

Electrical Apparatus: **Explosion-Proof Manual Call Point & Push Button**  
*Optional accessory:*

Type of Protection: **Ex d flameproof Protection**

Marking:  
Ex d IIC T4~T6 Gb  
Ex tb IIIC T135?~ T85 ? ( Tamb=-40 ? ~+70 ° C) IP66

*Approved for issue on behalf of the IECEx  
Certification Body:*

Asle Kaastad

*Position:*

Certification Manager

*Signature:  
(for printed version)*

*Date:*

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**NEMKO**  
Gautadelleen 30  
Oslo N-0314  
Norway





# IECEX Certificate of Conformity

Certificate No: IECEx NEM 14.0012X Issue No: 0  
Date of Issue: 2014-11-06 Page 2 of 4  
Manufacturer: **Moflash Signalling Ltd**  
Unit 18 Klaxon Industrial Estate, Tyseley  
Birmingham B11 2HA  
**United Kingdom**

Additional Manufacturing  
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0  
**IEC 60079-1 : 2007-04** Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition:6  
**IEC 60079-31 : 2008** Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t"  
Edition:1

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

#### Test Report:

CN/CQM/ExTR13.0043/00 NO/NEM/ExTR14.0016/00

#### Quality Assessment Report:

GB/SIR/QAR14.0001/00



# IECEx Certificate of Conformity

Certificate No: IECEx NEM 14.0012X

Issue No: 0

Date of Issue: 2014-11-06

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

This report covers two products, one is Manual Call Point type CP 125 and the other is a Push Button type PB 125. The difference is not involving the Ex protection principle. The product is made up of; main body and front cover both made in Stainless Steel, connected together by a spigot joint. There is actuator head screwed into the cover with an Ex threads of M20\*1,5. An operating rod pass through this and forms an Ex Cylindrical joints from the outside to the inside of the enclosure. 2 LEDs are installed in the lid by using cemented joint. There are micro switches, PCB's and a terminal row inside the housing.

#### Designation

CP 125 & PB 125 Series

#### Electrical Ratings:

30V DC 6A, 250 VAC 11A .

#### Degree of Protection

IP66.

### Ambient Variations

Product	Ambient temperature	Marking
CP 125 & PB 125	Tamb=-40°C~+70°C	Ex d IIC T4 Gb. Ex tb IIIC T135°C IP66.
	Tamb=-40°C~+60°C	Ex d IIC T5 Gb. Ex tb IIIC T100°C IP66.
	Tamb=-40°C~+55°C	Ex d IIC T6 Gb. Ex tb IIIC T85°C IP66.

### Routine Test

A routine pressure test according to EN 60079-1 clause 16 shall be carried out on all enclosures with the following pressures

CP 125 & PB 125      1.6MPa



# IECEX Certificate of Conformity

---

Certificate No: IECEx NEM 14.0012X

Issue No: 0

Date of Issue: 2014-11-06

Page 4 of 4

**CONDITIONS OF CERTIFICATION: YES as shown below:**

Repairs of the flameproof joints must be made in compliance with the structural specifications provided by the manufacturer. Repairs must not be made on the basis of values specified in tables 1 and 2 of EN/IEC 60079-1.